



Amy Harbert
Director

County of San Diego

Department of Environmental Health and Quality
Food and Housing Division
P.O. Box 129261, San Diego, CA 92112-9261
Phone: (858) 505-6659 | Fax: (858) 999-8920
www.sdcdehq.org

Heather Buonomo, REHS
Director of Environmental Health

PLAN APPROVAL SHEET

Record ID: DEH2021-FAMD-008801

Date: 10/26/2021

DBA: PHO MAI CALI AND GRILL

Address: 1635 SWEETWATER RD, NATIONAL CITY, CA 91950

Submitted By: LEEONEL SOLIS

Email: LEEONELSOLLIS@YAHOO.COM

Plans are approved by the Department of Environmental Health and Quality, Food and Housing Division (DEHQ-FHD) contingent upon the following:








- 1) DEHQ-FHD stamped plans must be maintained at the jobsite, followed during construction, and available for the Specialist to review at the time of inspection.
- 2) Changes to equipment layout, menu, or application must be submitted to DEHQ-FHD as a revision for prior approval. Changes made without approval will make the plan approval null and void.
- 3) All areas where open food is being prepared must be constructed to be fully enclosed. All openable windows must be equipped with fixed 16 mesh fly screens and exterior doors must be self-closing. Moveable wall/window systems, garage roll-up doors, or other means of rendering food processing areas not fully enclosed are not approved.
- 4) At the time of final inspection, all equipment is to be in place and functional, the facility shall have all utilities operational and all refrigeration shall be capable of maintaining foods at 41 degrees F or below and shall be equipped with a thermometer accurate to +/- 2 degrees F in the warmest section of the unit.
- 5) Obtain all applicable local building and safety authority permits and approvals prior to the final inspection by DEHQ-FHD.

CALL YOUR PLAN CHECK SPECIALIST OR THE SCHEDULING LINE AT (858) 505-6660 AT LEAST 10 WORKING DAYS IN ADVANCE TO SCHEDULE MID AND FINAL INSPECTIONS. A FINAL INSPECTION MUST BE CONDUCTED AND AN ENVIRONMENTAL HEALTH AND QUALITY PERMIT SHALL BE ISSUED PRIOR TO OPENING AND OPERATING THIS FOOD ESTABLISHMENT.

Nolberto Colon-Droz
Contact Info: (858) 505-6793, Nolberto.Colon-Droz@sdcounty.ca.gov

NOTES:

1. CHANGE IN FLOOR LEVEL AT DOORS. REGARDLESS OF THE OCCUPANT LOAD, THERE SHALL BE A FLOOR OR LANDING ON EACH SIDE OF A DOOR. THE FLOOR OR LANDING SHALL BE NO MORE THAN 1 INCH LOWER THAN THE THRESHOLD OF THE DOORWAY. WHERE A DOOR OPENS OVER A LANDING, THE LANDING SHALL BE AT LEAST AS WIDE AS THE DOOR, AND AT LEAST 5 FEET LONG. (Title 24, Part 2, Section 2-3303(i)(1) and (i)(2).)



AZTEC-CADinc
RESIDENTIAL DESIGN & DRAFTING
EMAIL: LEONEL29@GMAIL.COM
CELL: 619-414-8506

PHO MAI CALI
SUBMITTAL
563-161-70-00 1635 SWEETWATER RD.
NATIONAL CITY, CALIFORNIA 91950, SUITE H

Sealed

FLOOR PLAN
DETAILS



REVISION	
0	08/18/21
1	08/27/21

PROJECT NO. P0007
SHEET NO. 1